



Neschen Coating GmbH
Hans-Neschen-Straße
31675 Bückeburg
Germany

Your message - reference

-

our reference

JW/3271

Gent

2024-09-19

Certification report 24/3271

1. Description of the product:

Product type	Self-adhesive decorative wallcovering consisting of monomer plasticized, phthalate-free PVC-film backing coated with a high-tack water-based, age-resistant and permanently smooth elastic acrylate adhesive
Total mass	135 g/m ²
Thickness	0.1 mm

2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

addressee	our reference	Gent	page
Neschen Coating GmbH	JW/3271	2024-09-19	2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows according EN 13501-1:2018:

B – s1, d0
<i>if mounted over a plasterboard 13mm 700 kg/m³ or to substrates having a Euroclass A2-s1,d0 or A1 which density is superior to 525kg/m³</i>

The evaluation of this properties is based on evaluation scheme specified in EN 13501-1:2019: Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

Products falls under system 3 of assessment and verification of constancy of performance like declared by the manufacturer.

Related commercial names to this product group	Solvoprint® power tack 100
The obtained classification is based on the next test reports	CREPIM: DO-24-6453\A-R1 dd 16-09-2024
Validity of the certificate	15-09-2029

Jo Wynendaele, PhD
Consultant Floor and Wall Coverings

