

TEST CERTIFICATE

for the slip resistance of floor coverings
according to DIN EN 16165, Annex B

Tested material: **elastic coating**

Article description: High-quality, textured REACH and RoHS-compliant soft PVC film, transparent
Article number: filmolux easy clear sand
Kind of material: Polyvinyl chloride foil (PVC)
Dimensions: Length variable, width variable, d = 0.12 mm
Colour: transparent
Surface: according to specification: embossed (even, finely structured)
Producer/supplier: Neschen Coating GmbH
Hans-Neschen-Str. 1
31675 Bückeburg
Germany

Client: Neschen Coating GmbH
Hans-Neschen-Str. 1
31675 Bückeburg
GERMANY

Certificate No.: 104362501.001e
(tested under 99732301.001e)

Sample receipt: 17.04.2023

Test date: 18.04.2023

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 16165** (edition 02/2023)
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"
Annex B – Shod ramp test
The test sample was delivered in a surface condition ready for testing.

Test result: Angle value α_{shod} : **7°**

Assessment: **slip resistance class:** **R9**

SÄUREFLIESNER-VEREINIGUNG E. V.

Institut für Wand- und Bodenbeläge
Managing Director

Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 04.03.2025
Schu/ke

This test certificate is only valid for the above-mentioned test material.
The test certificate is issued for a period of 5 years (based on the test date).
The statement of conformity is based on the binary decision rule according to "ILAC-G8: 09/2019".
Publication and reproduction of the test certificate is only permitted in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (051 39) 99 82-0 · Telefax (051 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

