

## Progress, a passion to share

LABORATORY IN TRAPPES 29 avenue Roger Hennequin — 78197 Trappes Cedex Tel.: 01 30 69 10 00 —Fax: 01 30 69 12 34

## MATERIAL FIRE CLASSIFICATION REPORT

as defined in article 5 of the decree dated 21 November 2002

## **VALID FOR 5 YEARS from 8 July 2013**

N° P107247 - DE/7

and 4 pages in appendices

Material presented by: FILMOLUX SA

300 rue Etienne Marcel 93170 BAGNOLET

Trademark: SOLVOPRINT® PERFORMANCE CLEAR 80 GLOSS

**Summary description:** 

**Overall composition:** Flexible PVC polymer film with acrylic adhesive.

**Application:** Various applications **Mass:**  $(97 \pm 5) \text{ g/m}^2$  **Thickness:**  $(75 \pm 5) \text{ pm}$ 

Colouring: White

**Testing report:** N° P107247 - DE/7 of 8 July 2013

Nature of tests: Radiation test.

Classification: M 1 ADHESIVE ON 15/10e mm STEEL SHEET

## VALID FOR ANY APPLICATION FOR WHICH THE PRODUCT IS NOT SUBJECT TO CE MARKING

Durability of the classification (NF P 92-512: 1986): UNLIMITED IN PRINCIPLE

taking into account the criteria resulting from the tests described in testing report N° P107247 DE/7 in appendix

This report states only the characteristics of the sample tested and does not predict the characteristics of similar products. This is not a product certification as defined by article L. 115-27 of the consumer code and the law of 3 June 1994.

Reproduction is permitted only in full of either this Classification report which comprises 1 page or the entire Report and appendix which **comprise 5 pages.** 

Trappes, 8 July 2013

Manager of the Energy, Environment and Combustion Department

Noëlle LOFERME-PEDESPAN



Performance of testing Olivier LARADE Testing Manager

**Emilie COLIN - DENIAU** 



Accreditation NI' 1-0606 Scope available

on\_www.cofrac.fr